



Netzwerk 1:



E 24.6 E 24.6
E 41.3 E 41.3

LS802-2 LL NIVO V802
FS951 SEAL WATER LAAG


Netzwerk 2:



M 0.1 M 0.1

LOGISCHE "0"


Netzwerk 3:



M 0.0 M 0.0

LOGISCHE "1"

Netzwerk 4:



M 0.0 M 0.0

LOGISCHE "1"


Netzwerk 5:

A DB 100
L DW 16
T MW 206
L DW 116
T MW 204
L MB 16
T MB 200
U A 4.2 A 4.2
= M 201.0
U M 2.1 M 2.1
= M 201.1
U E 26.3 E 26.3
= M 201.2
U M 0.0 M 0.0
= M 201.3

A 4.2 A 4.2
E 26.3 E 26.3
M 0.0 M 0.0
M 2.1 M 2.1

MP802A START
MP802A CONTACTOR FEEDBACK
LOGISCHE "1"

Netzwerk 6:



FB 101 FB101

MOTOR 5

Netzwerk 7:

U M 201.0
= A 4.2 A 4.2
L MB 200
T MB 16
L MW 204
T DW 116
L MW 206
T DW 16

A 4.2

A 4.2

MP802A START

Netzwerk 8:

A DB 108
L MB 202
T DR 13
BE

Datei: METREX	Bearb.: M. Jordaen	Moxba - Metrex	RLD Automation
- PB 16 -	geprüft:		
St: 08.04.104 02:23:02	Datum: 24.11.2004		Blatt: 2