



Netzwerk 1:



M 0.1 M 0.1 LOGISCHE "0"

Netzwerk 2:



E 0.0 E 0.0 LS123 H NIVO B154

Netzwerk 3:



M 0.0 M 0.0 LOGISCHE "1"

Netzwerk 4:




M 0.0 M 0.0 LOGISCHE "1"

Netzwerk 5:

```
A      DB 100
L      DW 42
T      MW 206
L      DW 142
T      MW 204
L      MB 42
T      MB 200
U      A 6.0   A 6.0
=      M 201.0
U      M 2.1   M 2.1
=      M 201.1
U      E 12.0  E 12.0
=      M 201.2
U      M 0.0   M 0.0
=      M 201.3
***
```

A 6.0 A 6.0 MA150 START
E 12.0 E 12.0 MA150 CONTACTOR FEEDBACK
M 0.0 M 0.0 LOGISCHE "1"
M 2.1 M 2.1

Netzwerk 6:



FB 101 FB101 MOTOR 5

Netzwerk 7:

```
U      M 201.0
=      A 6.0   A 6.0
L      MB 200
T      MB 42
L      MW 204
T      DW 142
L      MW 206
T      DW 42
***
```

A 6.0 A 6.0 MA150 START

Netzwerk 8:

A	DB 108
L	MB 202
T	DR 26
BE	

Datei: METREX	Bearb.: M. Jordaen	Moxba - Metrex	RLD Automation
- PB 42 -	geprüft:		
St: 08.04.104 02:23:13	Datum: 24.11.2004		Blatt: 2