



Netzwerk 1:



M 0.1 M 0.1 LOGISCHE "0"

Netzwerk 2:



E 10.4 E 10.4 MA162 CONTACTOR FEEDBACK

Netzwerk 3:



M 0.0 M 0.0 LOGISCHE "1"

Netzwerk 4:




M 0.0 M 0.0 LOGISCHE "1"

Netzwerk 5:

```
A      DB 100
L      DW 44
T      MW 206
L      DW 144
T      MW 204
L      MB 44
T      MB 200
U      A 4.3   A 4.3
=      M 201.0
U      M 2.1   M 2.1
=      M 201.1
U      E 26.6  E 26.6
=      M 201.2
U      M 0.0   M 0.0
=      M 201.3
***
```

A 4.3 A 4.3 MA161 START
E 26.6 E 26.6 MA161 CONTACTOR FEEDBACK
M 0.0 M 0.0 LOGISCHE "1"
M 2.1 M 2.1

Netzwerk 6:



FB 101 FB101 MOTOR 5

Netzwerk 7:

```
U      M 201.0
=      A 4.3   A 4.3
L      MB 200
T      MB 44
L      MW 204
T      DW 144
L      MW 206
T      DW 44
***
```

A 4.3 A 4.3 MA161 START

Netzwerk 8:

A DB 108
L MB 202
T DR 27
BE

Datei: METREX	Bearb.: M. Jordaen	Moxba - Metrex	RLD Automation
- PB 44 -	geprüft:		
St: 08.04.104 02:23:15	Datum: 24.11.2004		Blatt: 2