


Netzwerk 1: ;MA-158




E 14.2 E 14.2 MA152.1 CONTACTOR FEEDBACK

Netzwerk 2:




M 0.1 M 0.1 LOGISCHE "0"

Netzwerk 3:



M 0.0 M 0.0 LOGISCHE "1"

Netzwerk 4:




M 0.0 M 0.0 LOGISCHE "1"

Netzwerk 5:

```
A      DB 100
L      DW 48
T      MW 206
L      DW 148
T      MW 204
L      MB 48
T      MB 200
U      A 6.6   A 6.6
=      M 201.0
U      M 2.1   M 2.1
=      M 201.1
U      E 12.6  E 12.6
=      M 201.2
U      M 0.0   M 0.0
=      M 201.3
***
```

A 6.6 A 6.6 MA158 START
E 12.6 E 12.6 MA158 CONTACTOR FEEDBACK
M 0.0 M 0.0 LOGISCHE "1"
M 2.1 M 2.1

Netzwerk 6:



FB 101 FB101 MOTOR 5

Netzwerk 7:

```
U      M 201.0
=      A 6.6   A 6.6
L      MB 200
T      MB 48
L      MW 204
T      DW 148
L      MW 206
T      DW 48
***
```

A 6.6 A 6.6 MA158 START

Netzwerk 8:

A DB 108
L MB 202
T DR 29
BE

Datei: METREX	Bearb.: M. Jordaen	Moxba - Metrex	RLD Automation
- PB 48 -	geprüft:		
St: 25.10.104 12:36:59	Datum: 24.11.2004		Blatt: 2