



Netzwerk 1:



E 24.3 E 24.3
 E 24.7 E 24.7
 E 41.3 E 41.3

LS800-3 HH NIVO V800A
 LS804-2 LL NIVO V804
 FS951 SEAL WATER LAAG


Netzwerk 2:



E 30.4 E 30.4

LS830-1 H NIVO V830


Netzwerk 3:



M 0.0 M 0.0

LOGISCHE "1"

Netzwerk 4:



M 0.0 M 0.0

LOGISCHE "1"


Netzwerk 5:

A DB 100
 L DW 54
 T MW 206
 L DW 154
 T MW 204
 L MB 54
 T MB 200
 U A 10.5 A 10.5
 = M 201.0
 U M 2.1 M 2.1
 = M 201.1
 U E 28.0 E 28.0
 = M 201.2
 U M 0.0 M 0.0
 = M 201.3

A 10.5 A 10.5
 E 28.0 E 28.0
 M 0.0 M 0.0
 M 2.1 M 2.1

MP805 START
 MP805 CONTACTOR FEEDBACK
 LOGISCHE "1"

Netzwerk 6:



FB 101 FB101

MOTOR 5

Netzwerk 7:

U M 201.0
= A 10.5 A 10.5
L MB 200
T MB 54
L MW 204
T DW 154
L MW 206
T DW 54

A 10.5 A 10.5

MP805 START

Netzwerk 8:

A DB 108
L MB 202
T DR 32
BE

Datei: METREX	Bearb.: M. Jordaan	Moxba - Metrex	RLD Automation
- PB 54 -	geprüft:		Blatt: 2
St: 08.04.104 02:23:22	Datum: 24.11.2004		