



Netzwerk 1: ;MA152.1



M 0.1 M 0.1 LOGISCHE "0"

Netzwerk 2:



M 0.1 M 0.1 LOGISCHE "0"

Netzwerk 3:



M 0.0 M 0.0 LOGISCHE "1"

Netzwerk 4:




M 0.0 M 0.0 LOGISCHE "1"

Netzwerk 5:

A DB 100
L DW 60
T MW 206
L DW 160
T MW 204
L MB 60
T MB 200
U A 8.2 A 8.2
= M 201.0
U M 2.1 M 2.1
= M 201.1
U E 14.2 E 14.2
= M 201.2
U M 0.0 M 0.0
= M 201.3

A 8.2 A 8.2 MA152.1 START
E 14.2 E 14.2 MA152.1 CONTACTOR FEEDBACK
M 0.0 M 0.0 LOGISCHE "1"
M 2.1 M 2.1

Netzwerk 6:



FB 101 FB101 MOTOR 5

Netzwerk 7:

U M 201.0
= A 8.2 A 8.2
L MB 200
T MB 60
L MW 204
T DW 160
L MW 206
T DW 60

A 8.2 A 8.2 MA152.1 START

Netzwerk 8:

A DB 108
L MB 202
T DR 35
BE

Datei: METREX	Bearb.: M. Jordaen	Moxba - Metrex	RLD Automation
- PB 60 -	geprüft:		
St: 25.10.104 13:17:06	Datum: 24.11.2004		Blatt: 2