

Netzwerk 1:



Netzwerk 2:



M 0.1 M 0.1 LOGISCHE "0"

Netzwerk 3:



M 0.0 M 0.0 LOGISCHE "1"

Netzwerk 4:




M 0.0 M 0.0 LOGISCHE "1"

Netzwerk 5:

```
A      DB 100
L      DW 75
T      MW 206
L      DW 175
T      MW 204
L      MB 75
T      MB 200
U      A 5.1      A 5.1
=      M 201.0
U      M 2.1      M 2.1
=      M 201.1
U      E 5.6      E 5.6
=      M 201.2
U      M 0.0      M 0.0
=      M 201.3
***
```

A 5.1 A 5.1 MP950 START
E 5.6 E 5.6 MP950 CONTACTOR FEEDBACK
M 0.0 M 0.0 LOGISCHE "1"
M 2.1 M 2.1

Netzwerk 6:



FB 101 FB101 MOTOR 5

Netzwerk 7:

```
U      M 201.0
=      A 5.1      A 5.1
L      MB 200
T      MB 75
L      MW 204
T      DW 175
L      MW 206
T      DW 75
***
```

A 5.1 A 5.1 MP950 START

Netzwerk 8:

A DB 108
L MB 202
T DL 42
BE

Datei: METREX	Bearb.: M. Jordaen	Moxba - Metrex	RLD Automation
- PB 75 -	geprüft:		
St: 08.04.104 02:23:35	Datum: 24.11.2004		Blatt: 2