

# **ReadWin 2000**

1.26.1.0

Verified: \_\_\_\_\_

## **Set-up**

19.05.17

### **PS640**

Unit type : Ceraphant PTC31 - PTP31/35  
Installation area :  
Additional information :  
Program name: : TXU01XA V01.01.01  
CPU/Serial no. : M2021601999  
Connected to : RLD-HPZBOOKB  
Communication : Serial (e.g. RS232 / RS485) / USB  
Com : 14  
Baudrate : 9600  
Databits : 8  
Parity : None  
Stopbits : 1  
Address : 01

### **Basic settings**

Unit: : kPa  
Position factor: : 0kPa  
Display: : Measured value  
Damping: : 0.0Sec

### **Output**

Output functions: : Hysteresis NO  
Switch point: : 260kPa  
Switch-back point: : 250kPa  
Delay switch point: : 1.0Sec  
Delay switch-back point: : 1.0Sec

### **Service settings**

Old password: : 0  
New password: : \*\*\*\*  
Static revision counter: : 8  
Device status: : 0  
Last diagnosis: : 209  
Simulation output: : OFF  
Max indicator: : 18kPa  
Min indicator: : 0kPa  
Switching cycles OUT 1: : 0

### **Identification**

TAG line 1: :  
TAG line 2: :  
Ordercode: : PTC31-A1A11P2AF1A  
Serial number: : M2021601999  
Serial number sensor: : M26FD501BE2  
Serial number electronics: : 739559-3  
Revision: : 01.05  
Hardware revision: : 01.00.02  
Software revision: : 01.01.01